

# Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017196	Cerabar S PMC71 PMC71-1BR1P1B4BAA	1	ST

010	Approval:	1	ATEX II 1/2G Ex ia IIC T6
020	Output; Operating:	B	4-20mA HART; inside + LCD
030	Housing; Cover Sealing; Cable Entry:	R	T17 316L hygiene IP66/68 NEMA6P;EPDM;M20 gland, T17 = side cover
040	Sensor Range; Sensor Overload Limit:	1P	10bar/1MPa/150psi gauge; 40bar/4MPa/600psi
050	Calibration; Unit:	1	Sensor range; mbar/bar
070	Process Connection:	B4	DN80 PN10-40 B1, 316L, flush mount flange EN1092-1 (DIN2527 D)
080	Seal:	B	EPDM
100	Additional Option 1:	A	Not selected
110	Additional Option 2:	A	Not selected