

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943492-9000	Liquiphant M FTL50H FTL50H-ATC2AD2G5C	1	ST

010	Approval:	A	Non-hazardous area
020	Process Connection:	TC2	Tri-Clamp ISO2852 DN25-38 (1...1-1/2"), 316L
030	Probe Length; Type:	AD	Compact; Ra<0.3um/12uin
040	Electronics; Output:	2	FEL52; SIL 3-wire PNP 10-55VDC
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	C	EN10204-3.1 material (316L wetted parts), inspection certificate