

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017196	Cerabar S PMC71 PMC71-AMA1P1TRAAA+Z1	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	M	PROFIBUS PA; extern + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	1P	10bar/1MPa/150psi gauge; 40bar/4MPa/600psi
050	Calibration; Unit:	1	Sensor range; mbar/bar
070	Process Connection:	TR	Varivent N tube DN40-162 PN40, 316L, flush mount, EHEDG, 3A available in combination with seal NBR/EPDM only
080	Seal:	A	FKM Viton
100	Additional Option 1:	A	Not selected
110	Additional Option 2:	A	Not selected
895	>>Marking:	Z1	Tagging (TAG), see additional spec.