

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017197	Cerabar S PMP75 PMP75-3NA1SB6CNAB4	1	ST
010	Approval:	3	ATEX II 1/2G Ex ia IIC + II 1/2D Ex ia IIC
020	Output; Operating:	N	PROFIBUS PA; inside + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	1S	40bar/4MPa/600psi gauge; 160bar/16MPa/2400psi
050	Calibration; Unit:	B	**Customised; see additional spec.
060	Membrane Material:	6	Rhodium>Gold>316L
070	Process Connection:	CN	DN25 PN10-40 B1, 316L, flush mount, flange EN1092-1 (DIN2527 D)
090	Transmitter Mounting; Fill Fluid:	A	Direct; silicone oil
100	Additional Option 1:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	4	Pressure test, internal procedure, test report