

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017196	Cerabar S PMC71 PMC71-AAA1SBYYAB4	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	A	4-20mA HART; extern + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	1S	40bar/4MPa/600psi gauge; 60bar/6MPa/900psi
050	Calibration; Unit:	B	**Customised; see additional spec.
070	Process Connection:	YY	Special version, TSP-no. to be spec.
080	Seal:	A	FKM Viton
100	Additional Option 1:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	4	Pressure test, internal procedure, test report