

# Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52017197	Cerabar S PMP75 PMP75-AAA1SB1EFYBN	1	ST

010	Approval:	A	Non-hazardous area
020	Output; Operating:	A	4-20mA HART; extern + LCD
030	Housing; Cover Sealing; Cable Entry:	A	T14 Alu IP66/67 NEMA6P; EPDM; M20 gland, T14 = side cover (Ex d > M20 thread)
040	Sensor Range; Sensor Overload Limit:	1S	40bar/4MPa/600psi gauge; 160bar/16MPa/2400psi
050	Calibration; Unit:	B	**Customised; see additional spec.
060	Membrane Material:	1	316L
070	Process Connection:	EF	DN50 PN100-160 E, 316L, flush mount, flange DIN2501
090	Transmitter Mounting; Fill Fluid:	Y	Special version, TSP-no. to be spec.
100	Additional Option 1:	B	3.1 Material certificate, wetted metallic parts, EN10204-3.1 inspection certificate
110	Additional Option 2:	N	HistoROM / M-DAT