

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
52005888	Liquiphant M FTL51C FTL51C-FCNSBS7G5AA	1	ST

010	Approval:	F	ATEX II 1/2GD Ex ia IIC T6, WHG/IECEEx zone 0/1
020	Process Connection:	CNS	DN80 PN25/40, Enamel>1.0487 flange EN1092-1 (DIN2527)
030	Probe Length; Type:	BS	600 mm mm; Enamel
040	Electronics; Output:	7	FEL57; SIL 2-wire PFM
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option 1:	A	Not selected
070	Additional Option 2:	A	Not selected