

## Configuration summary

Mat. no.	Description Order code	Quantity	Unit
943491-9000	Liquiphant M FTL51 FTL51-FBN2BB7G5A	1	ST

010	Approval:	F	ATEX II 1/2GD Ex ia IIC T6, WHG/IECEEx zone 0/1
020	Process Connection:	BN2	DN80 PN25/40 A, 316L flange EN1092-1 (DIN2527 B)
030	Probe Length; Type:	BB	800 mm ..... mm; 316L, Ra<3.2um/126uin
040	Electronics; Output:	7	FEL57; SIL 2-wire PFM
050	Housing; Cable Entry:	G5	F13 IP66/68 / F17 IP66/67 Alu; M20 gland (EEx d > M20 thread)
060	Additional Option:	A	Basic version